

**INTERGAS**

Švari energija. Jums!

2021 M. BALANDŽIO MĖNESIO

GAMTINIŲ DUJŲ VIRŠUTINIS ŠILUMINGUMAS MAŽEIKIŲ DUJŲ APSKAITOS STOTYJE

2021-05-03

Mažeikiai

2021 m. balandžio mėn.	Viršutinis šilumingumas kWh/m ³		Perskaičiavimo koeficientas
	0 C° matavimo	20 C° matavimo	
1	11,4544	10,6672	1,0738
2	11,4615	10,6738	1,0738
3	11,4649	10,6769	1,0738
4	11,4691	10,6809	1,0738
5	11,3805	10,5983	1,0738
6	11,3152	10,5375	1,0738
7	11,4531	10,6660	1,0738
8	11,465	10,6770	1,0738
9	11,4731	10,6846	1,0738
10	11,4776	10,6888	1,0738
11	11,4735	10,6850	1,0738
12	11,4707	10,6823	1,0738
13	11,3972	10,6139	1,0738
14	11,4797	10,6907	1,0738
15	11,4821	10,6930	1,0738
16	11,3266	10,5481	1,0738
17	11,3055	10,5285	1,0738
18	11,3597	10,5790	1,0738
19	11,3784	10,5964	1,0738
20	11,3856	10,6031	1,0738
21	11,3934	10,6104	1,0738
22	11,3341	10,5551	1,0738
23	11,3883	10,6056	1,0738
24	11,375	10,5932	1,0738
25	11,3137	10,5361	1,0738
26	11,2546	10,4811	1,0738
27	11,2378	10,4654	1,0738
28	11,233	10,4610	1,0738
29	11,2353	10,4631	1,0738
30	11,2365	10,4642	1,0738
Vidurkis	11,3825	10,6002	-

* Skirstymo sistemos operatoriaus viršutinio dujų šilumingumo vertės nurodytos esant norminėms sąlygoms: +25 °C degimo temperatūrai, +20°C matavimo temperatūrai ir 101,325 kPa absoliutiniam slėgiui bei esant sausoms dujoms.

