

2016-04-04

Mažeikiai

2016 m. kovo mėn.	Viršutinis šilumingumas kWh/m <sup>3</sup>		Perskaičiavimo koeficientas
	0 C° matavimo	20 C° matavimo	
1	11,7615	10,9532	1,0738
2	11,7670	10,9583	1,0738
3	11,7717	10,9627	1,0738
4	11,7808	10,9711	1,0738
5	11,7934	10,9829	1,0738
6	11,8126	11,0007	1,0738
7	11,7907	10,9804	1,0738
8	11,7633	10,9548	1,0738
9	11,7582	10,9501	1,0738
10	11,7656	10,9570	1,0738
11	11,7593	10,9511	1,0738
12	11,7588	10,9506	1,0738
13	11,7683	10,9595	1,0738
14	11,7735	10,9643	1,0738
15	11,7775	10,9681	1,0738
16	11,7869	10,9768	1,0738
17	11,7869	10,9768	1,0738
18	11,7791	10,9695	1,0738
19	11,7667	10,9580	1,0738
20	11,7673	10,9586	1,0738
21	11,7771	10,9677	1,0738
22	11,7965	10,9858	1,0738
23	11,8119	11,0001	1,0738
24	11,7982	10,9873	1,0738
25	11,7646	10,9560	1,0738
26	11,7317	10,9254	1,0738
27	11,7512	10,9436	1,0738
28	11,7412	10,9343	1,0738
29	11,7412	10,9343	1,0738
30	11,7403	10,9334	1,0738
31	11,7376	10,9309	1,0738
<b>Vidurkis</b>	<b>11,7703</b>	<b>10,9614</b>	-

\* Skirstymo sistemos operatoriaus viršutinio dujų šilumingumo vertės nurodytos esant norminėms sąlygoms: +25 °C degimo temperatūrai, +20°C matavimo temperatūrai ir 101,325 kPa absoliutiniam slėgiui bei esant sausoms dujoms.